



**NOTES:**

1. MANHOLE BASES, BARREL SECTIONS, CONES, AND GRADE RINGS SHALL BE CONSTRUCTED OF PRECAST REINFORCED CONCRETE CONFORMING TO ASTM C478.
2. MINIMUM DIAMETER OF THE BASE SECTION SHALL BE 60 INCHES, OR THE LARGEST PIPE DIAMETER + 24 INCHES, WHICHEVER IS GREATER.
3. MANHOLE COMPONENTS SHALL BE SUPPLIED WITH NO LADDER ASSEMBLIES.
4. PIPE OPENINGS SHALL BE CORE DRILLED OR BLOCKED OUT (CIRCULAR OPENINGS ONLY) AT THE TIME OF MANUFACTURE.
5. PIPE CONNECTIONS SHALL BE MADE WITH MANUFACTURED, FLEXIBLE, WATERTIGHT CONNECTORS.
6. MAXIMUM DISTANCE BETWEEN THE TOP OF THE CONE SECTION AND FINAL SURFACE GRADE SHALL NOT EXCEED 15".

<b>CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT</b>		
<b>LARGE DIAMETER PRECAST MANHOLE FOR PIPE LARGER THAN 24" DIAMETER</b>		
NO SCALE	FEBRUARY 2024	NO. 408