



CITY OF ALBANY
Public Works Department

ADDENDUM #1

SS-25-01, Cox Creek Interceptor Sewer Phase 3

DATE: MARCH 22, 2024

In order to clarify the intent of the Specifications and Drawings, the following provisions are provided and shall be considered part of the contract documents.

NEW BID OPENING DATE

Bids must be received by no later than **2:30 p.m., Tuesday, April 9, 2024**

I-16. OREGON DEPARTMENT OF TRANSPORTATION (ODOT) PERMIT

Add the following paragraph:

The Contractor will be responsible for obtaining a separate permit from ODOT for any dewatering activities located within the Interstate 5 right-of-way.

Item No. 5 – Sewer Bypass Pumping:

Add the following text at the end of the first paragraph:

Sewer bypass pumping may be operated on a continuous basis 24-hours per day, seven days per week.

Item No. 6 – Jack-and-Bore 36-Inch Steel Casing with 24-Inch PVC Carrier Pipe

Add the following paragraph:

The Contractor may elect to use a steel casing with a diameter larger than 36-inches. The Contractor may also elect to use alternative installation methods for installation of the steel casing pipe, with approval of the Engineer, including but not limited to closed face tunneling using a Micro Tunneling Boring Machine (MTBM). The Contractor will be responsible for all additional costs associated with and resulting from the use of a larger diameter casing pipe and any alternative installation method, and no additional contract time will be provided.

In order to ensure that all bidders are aware of these provisions, each bidder must sign this addendum below and attach it to the proposal.

IMPORTANT: Failure to include a signed Addendum could result in the disqualification of your bid.

Contractor's Signature

Date

Company Name *(please type or print)*